



Cleanroom Consulting Services
P.O. Box 394
Douglassville, Pennsylvania 19518
(800) 970-7629
(610) 385-1826 FAX

Certificate Of Compliance

Presented To:

Universal Protective Packaging, Inc.
61 Texaco Road, Mechanicsburg, Pennsylvania 17050

Main Cleanroom And Gowning Area
In The "At-Rest" Condition, At 0.5 μ Size

Per The Requirements Of ISO 14644-1 And/Or ISO 14664-2, The Above Listed Has Successfully Passed The Minimum Standards For An ISO-6 Class Cleanroom. Testing Was Performed As Outlined In The Above Standard. The Classification Is Applicable To The Area As Designated And Attested To In The Report Dated *February 2017*.

This Certificate Will Expire 6 Months From The Date Of Certification.

Date Of Certification: February 1, 2017

Certificate Expires: August 1, 2017

By: Richard C. Dewees

